

**NEVADA DIVISION OF ENVIRONMENTAL PROTECTION
FACT SHEET**

(Pursuant to NAC 445A.236)

Permittee: BK Motel Corporation
3410 Sandy Bowers Ave
Gardnerville NV 89410

Permit No.: NEV98026

Facility: Topaz Lake Inn
1929 Hwy 395 South
Douglas County
Latitude: 38° 41' 57" North
Longitude: 119° 32' 55" West
Township 10 N - Range 22 E - Section 29

General: Topaz Lake Inn is a 32 room motel that was constructed adjacent to the Topaz Nugget in 1999. A 10,000 gpd Santec package plant and leachfield were installed to serve the motel and casino. The enterprise then went bankrupt, and the Nugget was subsequently acquired by nearby Topaz Lodge and converted to a convention center (Topaz Lodge Convention Center). The convention center receives minimal usage and doesn't have kitchen facilities. Topaz Lodge is a motel casino with three restaurants, and is served by a separate package plant under discharge permit NEV50003.

The Santec plant was sized to accommodate the previously existing Topaz Nugget and a proposed 48 room motel. The Nugget had been served by a 4200 gpd septic tank leachfield system. Conversion of the Nugget to a convention center eliminated casino and restaurant flows, and the smaller than planned (32 room built vs 48 room proposed) motel has resulted in minimal flow and difficulty in meeting the effluent limitation for total nitrogen of 10 mg/l.

The Santec treatment processes consist of screening, equalization, aeration, denitrification, reaeration, clarification, sludge digestion, pH balance and methanol feed. The leachfield is split into two equal sized fields that are used in alternating fashion through manual operation of gate valves. Leachfield piezometers provide a check on the alternation frequency. The plant was designed to meet BOD/TSS/total nitrogen limits of 30/30/10 mg/l, respectively.

Receiving Water Characteristics: The depth to groundwater is 238 ft. The leachfield is within the 7000 ft well head protection zone of three public water supply wells; two serving Topaz Lodge and one serving Topaz Lake Inn. Two of the wells are within 500 ft and upgradient of the leachfield, the third is within 1000 ft and down or cross gradient.

Nevada Division of Environmental Protection
Fact Sheet

Topaz Lake Inn
 NEV98026
 Page 2 of 3

Rational for Permit Requirements:

Table I.A.1 - from draft permit NEV98026

| Parameter all units mg/l, except flow and pH | Discharge Limitations | Monitoring Requirements | | |
|----------------------------------------------------|--------------------------|-------------------------|--------------------------|-----------------------------|
| | | Sample Location | Measurement Frequency | Sample Type |
| flow, gpd | 10,000 | influent | continuous | pump timer or flow meter |
| BOD ₅ | 30 | effluent | quarterly | discrete |
| TSS | 30 | effluent | quarterly | discrete |
| Total Nitrogen | 10 | effluent | quarterly | discrete |
| pH, standard units | 6.0 - 9.0 | effluent | quarterly | discrete |
| Kjeldahl Nitrogen as N | m & r | effluent | quarterly | discrete |
| Nitrate as N | m & r | effluent | quarterly | discrete |
| Nitrite as N | m & r | effluent | quarterly | discrete |
| BOD ₅ | m & r | influent | quarterly | discrete |
| TSS | m & r | influent | quarterly | discrete |

Notes: BOD₅ = 5 day biochemical oxygen demand
 TSS = total suspended solids
 m & r = monitor and report
 Total nitrogen = Kjeldahl as N + nitrate as N + nitrite as N

The BOD and TSS limits are secondary standards. The total nitrogen limit has been imposed based on long standing nitrate contamination in the basin. The nitrogen species and influent BOD and TSS data are included to allow evaluation of the denitrification and secondary treatment processes.

Schedule of Compliance: The facility is required to meet the effluent limitations upon issuance of the permit.

Procedures for Public Comment: Notice of the Division's intent to renew discharge permit NEV98026, authorizing discharge of treated wastewater from Topaz Lake Inn and convention center to groundwater via leachfield, is being sent to the Nevada Appeal for publication. The notice is being mailed to interested persons on our mailing list. Anyone wishing to comment on the proposed permit must submit written comments to the Division within (30) days of the publication date. The comment period can be extended at the discretion of the Administrator. The deadline for receipt of all written comments is 5:00 pm Monday March 21, 2005. Comments postmarked prior to that deadline will also be accepted.

A public hearing on the proposed determination can be requested by the applicant, any affected state or interstate agency, the Regional Administrator, or any interested agency, person, or group of persons. The request must be filed within the comment period and indicate the interest of the person filing the request

Nevada Division of Environmental Protection
Fact Sheet

Topaz Lake Inn

NEV98026

Page 3 of 3

and the reasons why a hearing is warranted. Public hearings granted by the Division are conducted in accordance with NAC 445A.238.

The final determination of the Division may be appealed to the State Environmental Commission pursuant to NRS 445A.605.

Proposed Determination: The Division has made the tentative determination to renew the proposed discharge permit for a five year term.

Prepared by: Robert J. Saunders
 Staff Engineer
 Bureau of Water Pollution Control
 February 3, 2005